
Specifications:	SS-MPPT-15L		
Nominal Battery Voltage	12 V or 24 V		
Max. Solar Input Voltage	60 V		
Nominal Maximum Input Power	200 W / 400 W		
Maximum Battery Current	15 A		
Battery Voltage Range	7 – 36 V		
Rated Load Current	15 A		


Operational Configuration:




Switch 1: Battery Type














Set points for this switch setting can be modified with custom programming.

Contact Information:

Technical Support: Support.morningstarcorp.com

Phone: 1-215-321-4457

BATTERY SET POINTS 12-volt (24-volt)					
Set Point	GEL	Sealed	AGM	Flooded	
Absorption Voltage	14.0 V	14.1 V	14.3 V	14.4 V	
	(28.0 V)	(28.2 V)	(28.6 V)	(28.8 V)	
Float Voltage	13.7 V	13.7 V	13.7 V	13.7 V	
	(27.4 V)	(27.4 V)	(27.4 V)	(27.4)	
Time until Float	3 hours	3 hours	3 hours	3 hours	
Equalize Voltage	N/A	N/A	14.5 V	14.9 V	
Equalize Duration	N/A	N/A	3 hours	3 hours	
Equalize Calendar (days)	N/A	N/A	28	28	
Maximum Regulation Voltage*	15 V (30 V)				
LVD**/ LVR** (Switch 2 OFF)	11.5 V /12.6 V @ 12 V (23.0 V/25.2 V @ 24 V)				
LVD**/LVR** (Switch 2 ON)	11.0 V/12.1 V @ 12 V (22.0 V/24.2 V @ 24 V)				
Load HVD**	15.3 V (30.6 V)				
Load HVR**	14.5 V (29 V)				
Array HVD (Temp. Comp.)	Highest voltage set point + 0.5 V				
Array HVR (Temp. Comp.)	13.8 V (27.6 V)				

^{*}Not temperature compensated. 15 V @ 12 V nominal, 30 V @ 24 V nominal. ** Adjustable by DIP Switch 2. Not temperature compensated. Can be modified in custom settings.

For Custom Programming:

Use the software available at https://www.morningstarcorp.com/msview/.

I See the SunSaver MPPT Installation, Operations, and Maintenance Manual for additional information/guidance.

Switch 2: Load Control / **Low Voltage Disconnect/Reconnect**




LVD = 11.5 V LVR = 12.6 V



ON² LVD = 11.0 V LVR = 12.1 V

Switch 3: Auto-Equalization







Auto-Equalize ON (AGM, Flooded Battery Types only)

Switch 4: Communication Mode -Meter/MODBUS®



Remote Meter, & Relay Driver



MODBUS® Protocol for MSView, Ethernet Meterbus Converter, 3rd-Party Devices





SOLAR CONTROLLER SS-MPPT-15L

Quick Start Guide



Scan QR Code to go directly to the **SunSaver MPPT Installation Manual** and warranty information online.









Safety Information:



WARNING: Shock Hazard

The SunSaver MPPT controller must be installed by a qualified technician in accordance with the electrical regulations of the country of installation.



WARNING: Shock Hazard

This unit is not provided with a GFDI device. This charge controller must be used with an external GFDI device as required by the Article 690 of the National Electrical Code for the installation location.



IMPORTANT: READ the SunSaver MPPT Installation Manual for safety and regulatory information, instructions on configuration and operation, and warranty information.

Warranty Registration: https://www.morningstarcorp.com/product-registration/

TIT

Screws (x4)

In the Box:

Tools Required:

Multimeter

MS-003294 SS-MPPT QSG (3/16/2021) Rev C03

#2 Philips Screwdriver

Drill with a 3/32" (2.5 mm) bit





3/16 (5 mm) & 3/32" (2.5 mm) Flathead Screwdriver

Optional Accessories:



Remote Temperature Sensor (RTS)



Relay Driver (RD-1)



Remote Meter (RM-1)





PC MeterBus Adapter (MSC)



Converter (EMC-1)



USB Communications Adapter (UMC-1)

² These values can be modified with custom programming.

SunSaver MPPT™ Charge Controller

Quick Start Guide

Adapter (MSC)

Status

Equalize Charge

Absorption

Charge

Float Charge

Nearly Full

Half Full

Battery Low

Battery Empty

Residential

Communications

Adapter (UMC-1)

Load Status

Load ON

Load ON

Load ON

Load ON


Load ON

LVD Warning

(Load On)

LVD (Load Off)

Industrial





WARNING: Explosion Hazard

Never install the SunSaver MPPT in an enclosure with vented/flooded batteries. Battery fumes are flammable and will corrode and destroy the SunSaver circuits.



WARNING: Risk of Fire


If a Remote Temperature Sensor (RTS) is NOT connected, locate the SunSaver MPPT within 3 m (10 ft) of the batteries. Internal temperature compensation will be used if the RTS is not connected. Use of the RTS is strongly recommended.



Mounting:

CAUTION: Equipment Damage

Do not expose the SunSaver MPPT to weather. Locate in a dry, protected area to prevent equipment damage. Ensure the minimum clearance requirements are followed to provide adequate ventilation and prevent the unit from overheating.



Operating Color Indication State OFF (with heartbeat1) None Night ON Solid (with heartbeat²) Charging Green Red Flashing Frror Red ON Solid (with heartbeat²) Critical Error heartbeat indication flickers the Status LED **ON** briefly every 5 seconds

² heartbeat indication flickers the Status LED **OFF** briefly every 5 seconds

IMPORTANT: Example only. Actual wiring may vary. READ the SunSaver **Battery SOC LEDs** Status LED MPPT Installation, Operations, and Maintenance Manual for mandatory safety requirements. All configuration must comply with local and national electric codes. Consult your local electric authority to ensure compliance. SUNSAVER MPPT MORNINGSTAR **Optional Accessories** Remote Meter (RM-1) **Solar Disconnect*** RJ-11 (PV GFP required per Cable **NEC 690)** Green Green 🔵 5 Remote **Temperature** Green 🦱 Sensor Green 🔵 Yellow 🦳 **DC Load Disconnect*** Red 🔘 Battery (+) Battery (—) Red

(-)**Battery / Battery Bank Primary System**

Wiring and Torque Requirements Recommended Order of Wire Size Wire Size Wire Size Torque Component **Tool Required** Installation (Maximum (1) **Load Terminals** #6 AWG #6 AWG #8 AWG 3/16"(5 mm) 10.6 in-lbs. (2) **Battery Terminals** 16 mm² 10 mm² 16 mm (1.2 Nm) Flathead Screwdriver Maximum) (Maximum) (Maximum (3) Solar Terminals #22 AWG / 0.3 mm² (Minimum) 3.5 in-lbs. 3/32" (2.5 mm) Remote Temperature 4 #12 AWG / 3.0 mm² (Maximum) Flathead Screwdriver (0.4 Nm) Sensor

connections have been completed.

*Fuse or breaker sizing must be based on required wire ampacity.

If using a fuse, do NOT insert the fuse in the fuse-holder until after all the other

Security Communications

DC Load(s)*

WARNING: Shock Hazard

Lighting

Fthernet

MeterBus

Converter

Indication

Fast Flashing (2 Flash / sec)

Medium Flashing (1 Flash / sec)

Slow Flashing (1 Flash / 2 sec)

ON Solid

ON Solid

Flashing (1 Flash / sec)

ON Solid

BATTERY STATE-OF-CHARGE (SOC) LEDs

Relay Driver

(RD-1)

SOC

LED

Test between all terminals and ground before touching.

Power or accessory terminals are **NOT** electrically isolated from DC input and may be energized with hazardous solar voltage.

Ground

WARNING: Shock Hazard

Fuses, circuit breakers, and disconnect switches never open grounded system conductors. Only GFDI devices are permitted to disconnect grounded conductors.



IMPORTANT:

Ensure there is only 1 DC Negative-to-Ground Bond in the entire system.

Power UP Sequence:

LEGEND Negative (-)

Positive (+)


Ground

2. Connect Solar.

- 1. Connect Battery/Battery Bank.

Power DOWN Sequence:

- Disconnect Solar.
- 2. Disconnect Battery/Battery Bank.



Step 5: Secure Controller Place the controller on the surface and align the mounting holes with the drilled holes in step 4. Secure the controller in place using the Mounting screws (included).

Fuses or Disconnects

5

Battery

Disconnect*